



**ESSEX COUNTY**  
**OFFICE OF THE MANAGER**

7551 Court Street · P.O. Box 217 · Elizabethtown, New York 12932  
Telephone (518) 873-3332 · Fax (518) 873-3339

Daniel L. Palmer  
County Manager

Linda M. Wolf  
Purchasing Agent

**TO:** All Bidders

**FROM:** Linda Wolf, CPA, Purchasing Agent

**DATE:** June 22, 2017

**SUBJECT:** Addendum #1 Courthouse Heating System Repairs

**This Addendum, issued to bid document holders of record, indicates changes to the bid documents for the Courthouse Heating System Repairs Bid Opening July 7, 2017.**

Following is a list of scope changes after pre-bid walkthrough:

**Drawing H202- First Floor Piping Plan**

Location K- In addition to replacing the supply and return unions as stated, replace 2" dielectric unions with mated steel and copper flanges with a TFE gasket. The copper flange to be a sweated and the steel flange to be press on.

**Drawing H203- Second Floor Piping Plan**

Location N- The piping in this area is steel. The scope stays the same for this location except the flanges, valves and drain fittings change from brass/copper to steel.

Location U- Essex County DPW will remove a portion of firewall to allow access to replace the dielectric unions as outlined in the scope for this location.

END OF ADDENDUM # 1

