

ESSEX COUNTY OFFICE OF THE MANAGER

> 7551 Court Street · P.O. Box 217 · Elizabethtown, New York 12932 Telephone (518) 873-3332 · Fax (518) 873-3339

Daniel L. Palmer County Manager Linda M. Wolf Purchasing Agent

TO: All Bidders

FROM: Linda Wolf, CPA, Purchasing Agent

DATE: June 5, 2023

SUBJECT: Addendum #1 TRACY ROAD CULVERT REPLACEMENT

This Addendum, issued to bid document holders of record, indicates changes to the bid documents for the *Tracy Road Culvert Replacement* Bid Opening June 8, 2023.

PLEASE NOTE that the Bid Opening date has been extended until June 15, 2023 at 2:00 PM.

PLEASE SEE the following Questions and Answers:

QUESTION:

Are the piles of stone fill, subbase, and bedding material near the culvert sections for this project? What aggregate do we need to supply?

ANSWER:

Materials on site may be used by the contractor. Contractor to verify all quantities. All additional materials are to be supplied by the contractor per the plans and specifications.

QUESTION:

Does the 595 item membrane cover the entire top of the culvert and/or just the side joints and/or the side & top joints?

ANSWER:

Membrane is to be applied to the entire top and sides of the culvert not just the joints.

QUESTION:

Is any rigging being provided by Essex County of Fort Miller?

ANSWER:

No rigging will be supplied by Essex County or Fort Miller. The contractor will be required to make arrangements for lifting structures with the lifting holes shown on the details.

END OF ADDENDUM # 1