

# ADDENDUM NO. 1

## 2012 COUNTY COMPLEX COLUMN REPAIRS

Essex County, NY

December 20, 2012

### TO ALL HOLDERS OF BIDDING DOCUMENTS:

This Addendum, issued to bid document holders of record, indicates clarifications to the bid documents for the 2012 County Complex Column Repairs project. All clarifications described herein shall be incorporated into the Contractor's bid proposal. This Addendum is part of the Contract Documents. Adjustments required by each item shall be understood to apply to all document references affected by the clarifications described.

1. **Regarding Drawing S-4, TYPICAL REPAIR DETAILS: CHANGE the GENERAL note to read as follows, (changes are in bold):**

General: Remove all water damaged portions of existing wood. Apply necessary repairs as shown. All repair/restoration work shall follow the Secretary of the Interior's Standards for Rehabilitation and Guidelines for Rehabilitation for Historic Buildings. Repair quantity shall include an average of (10) wood stave boards replaced with new **per column**, extending from base to **18"** vertically at all **(4)** columns. Final replacement quantities shall be at direction of Engineer. New wood profiles shall match existing & sand surface smooth to match existing & to be painted."

END OF ADDENDUM NO. 1