

ESSEX COUNTY  
MOUNT DEFIANCE  
TELECOMMUNICATIONS SHELTER ALTERATIONS  
AES PROJECT NO. 3808

**DOCUMENT 00910**

**ADDENDA**

**ADDENDUM NUMBER 2**

**DATE:** October 1, 2012  
**PROJECT:** Mount Defiance Telecommunications Shelter Alterations  
**AES PROJECT NO:** 3808  
**OWNER:** Essex County  
**ARCHITECT:** AES Northeast, PLLC  
**TO:** Prospective Bidders/Plan Holders

This Addendum forms a part of the Contract Documents and modifies the Documents dated August 24, 2012, Addendum No. 1 dated September 26, 2012, with amendments and additions noted below.

Acknowledge receipt of this Addendum in the space provided in the Bid Form. Failure to do so may disqualify the Bidder.

**This Addendum consists of (1) Page.**

**QUESTIONS**

Question No. 1 What Tower Classification should be used for the estimate, Class 1, 11 or 111?

**ANSWER Tower classification III.**

Question No. 2 What is the ridge height since the Topography Category requested is 4?

**ANSWER Ridge height is 450 ft.**

Question No. 3 What are the line sizes running to the antennas and dishes?

**ANSWER Flexwell standard elliptical waveguide E65 will be used for the 6' dish to be mounted on the antenna support structure.**

END DOCUMENT