



ESSEX COUNTY

OFFICE OF THE MANAGER

7551 Court Street · P.O. Box 217 · Elizabethtown, New York 12932
Telephone (518) 873-3332 · Fax (518) 873-3339

Daniel L. Palmer
County Manager

Linda M. Wolf
Purchasing Agent

TO: All Bidders

FROM: Linda Wolf, CPA, Purchasing Agent

DATE: May 15, 2013

SUBJECT: Addendum #2 MEDIUM VOLTAGE TRANSFORMER

This Addendum, issued to bid document holders of record, indicates changes to the bid documents for the *Medium Voltage Transformer Bid Opening May 15, 2013.*

Please note the following changes regarding the high voltage bushing configuration for loop feed style for the installation of M.O.V.E. elbow arrestors:

**Specification Section 261200 Medium Voltage Transformers
Part 2.1 Paragraph M.**

Remove: Paragraph 1.b.1 in its entirety.

Insert: 15/25 kV Loop Feed deadfront: The Transformer shall be provided with six (6) high voltage bushings in accordance with ANSI C57.12.34 dimensions for loop feed configurations.

END OF ADDENDUM #2