

ESSEX COUNTY
GOVERNMENT CENTER
ROOF REPLACEMENT (PHASE 1)
AES PROJECT NO. 4214

DOCUMENT 009100

ADDENDA

ADDENDUM NUMBER 2

DATE: August 6, 2014
PROJECT: Government Center Roof Replacement (Phase 1)
AES PROJECT NO: 4214
OWNER: Essex County
ARCHITECT: AES Northeast, PLLC
TO: Prospective Contractors

This Addendum forms a part of the Contract Documents and modifies the Documents dated July 9, 2014 and Addendum No. 1 dated July 28, 2014, with amendments and additions noted below.

Acknowledge receipt of this Addendum in the space provided in the Bid Form. Failure to do so may disqualify the Contractor.

This Addendum, consists of (1) page total; DOCUMENT 009100 – ADDENDUM NO. 2, (1) page.

QUESTIONS

Question No. 1: Since the flat roof deck is gypsum, can the insulation be attached with adhesive instead of mechanically attached?

ANSWER: Yes, attaching the insulation with adhesive is acceptable, given it meets the specified warranty.

END OF DOCUMENT