



# **ESSEX COUNTY**

## **OFFICE OF THE MANAGER**

7551 Court Street · P.O. Box 217 · Elizabethtown, New York 12932  
Telephone (518) 873-3332 · Fax (518) 873-3339

---

Daniel L. Palmer  
County Manager

Linda M. Wolf  
Purchasing Agent

**TO:** All Bidders

**FROM:** Linda Wolf, CPA, Purchasing Agent

**DATE:** December 11, 2017

**SUBJECT:** Addendum #1 PSB WATER METER MATERIALS

**This Addendum, issued to bid document holders of record, indicates changes to the bid documents for the *PSB Water Meter Materials Bid Opening December 20, 2017.***

**Please add the following to Section 400506, 2.1 PIPING ACCESSORIES:**

**A.1. Pressure Reducing Valve**

1. Manufacturer: Cla-Val Model 90-01/690-01 or equal
2. Valve Body and Cover: Ductile Iron
3. Pattern: Angle configuration
4. Pressure Class: 300, 400 psi rating
5. Disc guide and seat: Bronze
6. Disc: Buna-N Rubber
7. Diaphragm: Nylon Reinforced Buna-N Rubber
8. Stem, Nut and Spring: Stainless Steel
9. Main Valve Inlet/Outlet: 2" threaded
10. Pilot: Bronze ASTM B62
11. Pilot Pressure adjustment range: 20 to 105 psi
12. Optional Features: Pressure Gauges: 2.5", 0-200 psi
13. Optional features: Pilot "Y" strainer, pilot isolation valves (all ports), Flow control (Open and Closing), and valve position indicator.

END OF ADDENDUM # 1