



ESSEX COUNTY

OFFICE OF THE MANAGER

7551 Court Street · P.O. Box 217 · Elizabethtown, New York 12932
Telephone (518) 873-3332 · Fax (518) 873-3339

Daniel L. Palmer
County Manager

Linda M. Wolf
Purchasing Agent

TO: All Bidders

FROM: Linda Wolf, CPA, Purchasing Agent

DATE: April 3, 2018

SUBJECT: Addendum #1 CARPET REMOVAL OVER ASBESTOS TILE

This Addendum, issued to bid document holders of record, indicates changes to the bid documents for the *Carpet Removal Over Asbestos Tile Bid Opening April 27, 2018.*

Please note that removal of approximately 120 square feet of 9" tile shall be included with the carpet removal. Please see attached AmeriSci PLM Bulk Asbestos Report.

END OF ADDENDUM # 1



Please Reply To:

AmeriSci New York

117 EAST 30TH ST.

NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-3114

FACSIMILE TELECOPY TRANSMISSION

To: Christian Fout
Atlantic Testing Laboratories, Limited

Fax #:

Email: ameriscipl@atlantictesting.com

From: Ella Babayeva
AmeriSci Job #: 217061637
Subject: ELAP-PLM/TEM 5 day Results
Client Project: PL5689; Essex Co. Gov. Ctr.;
Social Services Wing,
Elizabethtown, NY

Date: Thursday, June 08, 2017

Time: 10:06:55

Comments:

Number of Pages: 7

(including cover sheet)

CONFIDENTIALITY NOTICE: Unless otherwise indicated, the information contained in this communication is confidential information intended for use of the individual named above. If the reader of this communication is not the intended recipient, you are hereby notified that any dissemination, distribution or copying of this communication is prohibited. If you have received this communication in error, please immediately notify the sender by telephone and return the original message to the above address via the US Postal Service at our expense. Samples are disposed of in 60 days or unless otherwise instructed by the protocol or special instructions in writing. Thank you.

Certified Analysis

Service 24 Hours A Day • 7 Days A Week

Competitive Prices

visit our web site - www.amerisci.com

Boston • Los Angeles • New York • Richmond



AmeriSci New York

117 EAST 30TH ST.
NEW YORK, NY 10016
TEL: (212) 679-8600 • FAX: (212) 679-3114

PLM Bulk Asbestos Report

Atlantic Testing Laboratories, Limited
Attn: Christian Fout
P.O. Box 29

Canton, NY 13617

Date Received 06/05/17 **AmeriSci Job #** 217061637
Date Examined 06/07/17 **P.O. #** 14644
ELAP # 11480 **Page** 1 of 3
RE: PL5689; Essex Co. Gov. Ctr.; Social Services Wing,
Elizabethtown, NY

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
PL5689AB01A-060217 01	217061637-01 Location: Basement - Kitchen - Light Green 9 x 9 Floor Tile	Yes	6.6 % (by NYS ELAP 198.6) by Ella Babayeva on 06/07/17
Analyst Description: Light Green, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Chrysotile 6.6 % Other Material: Non-fibrous 34.9 %			
PL5689AB01B-060217 01	217061637-02 Location: Basement - Corridor - Light Green 9 x 9 Floor Tile		NA/PS
Analyst Description: Bulk Material Asbestos Types: Other Material:			
PL5689AB02A-060217 02	217061637-03 Location: Basement - Kitchen - Black Mastic On 01	Yes	3.6 % (by NYS ELAP 198.6) by Ella Babayeva on 06/07/17
Analyst Description: Black, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Chrysotile 3.6 % Other Material: Non-fibrous 32 %			
PL5689AB02B-060217 02	217061637-04 Location: Basement - Corridor - Black Mastic On 01		NA/PS
Analyst Description: Bulk Material Asbestos Types: Other Material:			
PL5689AB03A-060217 03	217061637-05 Location: Basement - Corridor - Brown 12 x 12 Floor Tile With White Streaks	No	NAD (by NYS ELAP 198.6) by Ella Babayeva on 06/07/17
Analyst Description: Brown/White, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 14 %			

Client Name: Atlantic Testing Laboratories, Limited

PLM Bulk Asbestos ReportPL5689; Essex Co. Gov. Ctr.; Social Services Wing,
Elizabethtown, NY

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
03 PL5689AB03B-060217	217061637-06	No	NAD (by NYS ELAP 198.6) by Ella Babayeva on 06/07/17
Location: Basement - Corridor - Brown 12 x 12 Floor Tile With White Streaks			
Analyst Description: Brown/White, Homogeneous, Non-Fibrous, Bulk Material			
Asbestos Types:			
Other Material: Non-fibrous 12.4 %			
04 PL5689AB04A-060217	217061637-07	No	NAD (by NYS ELAP 198.6) by Ella Babayeva on 06/07/17
Location: Basement - Corridor - Yellow Mastic On 03			
Analyst Description: Yellow, Homogeneous, Non-Fibrous, Bulk Material			
Asbestos Types:			
Other Material: Non-fibrous 22.6 %			
04 PL5689AB04B-060217	217061637-08	No	NAD (by NYS ELAP 198.6) by Ella Babayeva on 06/07/17
Location: Basement - Corridor - Yellow Mastic On 03			
Analyst Description: Yellow, Homogeneous, Non-Fibrous, Bulk Material			
Asbestos Types:			
Other Material: Non-fibrous 46.5 %			
05 PL5689AB05A-060217	217061637-09	Yes	5.8 % (by NYS ELAP 198.6) by Ella Babayeva on 06/07/17
Location: Basement - Corridor - Cream 12 x 12 Floor Tile With Brown Streaks			
Analyst Description: Cream, Homogeneous, Non-Fibrous, Bulk Material			
Asbestos Types: Chrysotile 5.7 %			
Other Material: Non-fibrous 38.8 %			
05 PL5689AB05B-060217	217061637-10		NA/PS
Location: Basement - Corridor - Cream 12 x 12 Floor Tile With Brown Streaks			
Analyst Description: Bulk Material			
Asbestos Types:			
Other Material:			
06 PL5689AB06A-060217	217061637-11	No	NAD (by NYS ELAP 198.6) by Ella Babayeva on 06/07/17
Location: Basement - Corridor - Yellow Mastic On 05			
Analyst Description: Yellow, Homogeneous, Non-Fibrous, Bulk Material			
Asbestos Types:			
Other Material: Non-fibrous 19.2 %			


Client Name: Atlantic Testing Laboratories, Limited

PLM Bulk Asbestos Report

PL5689; Essex Co. Gov. Ctr.; Social Services Wing,
 Elizabethtown, NY

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
PL5689AB06B-060217 06	217061637-12 Location: Basement - Corridor - Yellow Mastic On 05	No	NAD (by NYS ELAP 198.6) by Ella Babayeva on 06/07/17
Analyst Description: Yellow, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 17.6 %			

Reporting Notes:

Analyzed by: Ella Babayeva 

*NAD/NSD =no asbestos detected; NA =not analyzed; NA/PS =not analyzed/positive stop, (SOF-V) = Sprayed On Fireproofing containing Vermiculite; (SM-V) = Surfacing Material containing Vermiculite; PLM Bulk Asbestos Analysis by EPA 600/M4-82-020 per 40 CFR 763 (NVLAP 200546-0), ELAP PLM Method 198.1 for NY friable samples, which includes the identification and quantitation of vermiculite or 198.6 for NOB samples or EPA 400 pt ct by EPA 600/M4-82-020 (NY ELAP Lab 11480); Note:PLM is not consistently reliable in detecting asbestos in floor coverings and similar non-friable organically bound materials. NAD or Trace results by PLM are inconclusive, TEM is currently the only method that can be used to determine if this material can be considered or treated as non asbestos-containing in NY State (also see EPA Advisory for floor tile, FR 59,146,38970,8/1/94) National Institute of Standards and Technology Accreditation requirements mandate that this report must not be reproduced except in full without the approval of the lab.This PLM report relates ONLY to the items tested. AIHA-LAP, LLC Lab ID 102843, RI Cert AAL-094, CT Cert PH-0186, Mass Cert AA000054.

Reviewed By: _____ END OF REPORT _____

Table I
Summary of Bulk Asbestos Analysis Results
 PL5689; Essex Co. Gov. Ctr.; Social Services Wing, Elizabethtown, NY

AmeriSci Sample #	Client Sample#	HG Area	Sample Weight (gram)	Heat Sensitive Organic %	Acid Soluble Inorganic %	Insoluble Non-Asbestos Inorganic %	** Asbestos % by PLM/DS	** Asbestos % by TEM
01	PL5689AB01A-060217	01	0.200	28.0	30.5	34.9	Chrysotile 6.6	NA
Location:	Basement - Kitchen - Light Green 9 x 9 Floor Tile							
02	PL5689AB01B-060217	01	0.221	24.4	24.4	51.1	NA/PS	NA
Location:	Basement - Corridor - Light Green 9 x 9 Floor Tile							
03	PL5689AB02A-060217	02	0.104	48.1	16.3	32.0	Chrysotile 3.6	NA
Location:	Basement - Kitchen - Black Mastic On 01							
04	PL5689AB02B-060217	02	0.246	28.0	24.4	47.6	NA/PS	NA
Location:	Basement - Corridor - Black Mastic On 01							
05	PL5689AB03A-060217	03	0.235	20.9	65.1	14.0	NAD	NAD
Location:	Basement - Corridor - Brown 12 x 12 Floor Tile With White Streaks							
06	PL5689AB03B-060217	03	0.185	21.1	66.5	12.4	NAD	NAD
Location:	Basement - Corridor - Brown 12 x 12 Floor Tile With White Streaks							
07	PL5689AB04A-060217	04	0.164	37.8	39.6	22.6	NAD	NAD
Location:	Basement - Corridor - Yellow Mastic On 03							
08	PL5689AB04B-060217	04	0.187	24.6	28.9	46.5	NAD	NAD
Location:	Basement - Corridor - Yellow Mastic On 03							
09	PL5689AB05A-060217	05	0.213	27.7	27.7	38.8	Chrysotile 5.7	NA
Location:	Basement - Corridor - Cream 12 x 12 Floor Tile With Brown Streaks							
10	PL5689AB05B-060217	05	0.161	25.5	31.7	42.9	NA/PS	NA
Location:	Basement - Corridor - Cream 12 x 12 Floor Tile With Brown Streaks							
11	PL5689AB06A-060217	06	0.146	58.9	21.9	19.2	NAD	NAD
Location:	Basement - Corridor - Yellow Mastic On 05							
12	PL5689AB06B-060217	06	0.108	51.9	30.6	17.6	NAD	NAD
Location:	Basement - Corridor - Yellow Mastic On 05							

Client Name: Atlantic Testing Laboratories, Limited

Table I
Summary of Bulk Asbestos Analysis Results

PL5689; Essex Co. Gov. Ctr.; Social Services Wing, Elizabethtown, NY

AmeriSci Sample #	Client Sample#	HG Area	Sample Weight (gram)	Heat Sensitive Organic %	Acid Soluble Inorganic %	Insoluble Non-Asbestos Inorganic %	** Asbestos % by PLM/DS	** Asbestos % by TEM
-------------------	----------------	---------	----------------------	--------------------------	--------------------------	------------------------------------	-------------------------	----------------------

Analyzed by: Samuel X. Zhang, *Samuel X. Zhang*; Date Analyzed 6/8/2017

**Quantitative Analysis (Semi/Full): Bulk Asbestos Analysis - PLM by EPA 600/M4-82-020 per 40 CFR or ELAP 198.1 for New York friable samples or ELAP 198.6 for New York NOB samples; TEM (Semi/Full) by EPA 600/R-93/116 (not covered by NVLAP Bulk accreditation) or ELAP 198.4; for New York samples; NAD = no asbestos detected during a quantitative analysis; NA = not analyzed; Trace = <1%; (SOF-V) = Sprayed On Fireproofing containing Vermiculite; (SM-V) = Surfacing Material containing Vermiculite; Quantitation for beginning weights of <0.1 grams should be considered as qualitative only; Qualitative Analysis: Asbestos analysis results of "Present" or "NVA = No Visible Asbestos" represents results for Qualitative PLM or TEM Analysis only (no accreditation coverage available from any regulatory agency for qualitative analyses); NVLAP (PLM) 200546-0, NYSDOH ELAP Lab 11480, AIHA-LAP, LLC (PLM) Lab ID 102843.

Warning Note: PLM limitation, only TEM will resolve fibers <0.25 micrometers in diameter. TEM bulk analysis is representative of the fine grained matrix material and may not be representative of non-uniformly dispersed debris for which PLM evaluation is recommended (i.e. soils and other heterogeneous materials).

Reviewed By: _____



ATLANTIC TESTING LABORATORIES

ASBESTOS BULK SAMPLE CHAIN-OF-CUSTODY RECORD

14644

Albany 22 Corporate Drive Clifton Park, NY 12065 518/383-9144 (T) 518/383-9166 (F)

Binghamton 126 Park Avenue Binghamton, NY 13903 607/773-1812 (T) 607/773-1835 (F)

Canton 6431 U.S. Highway 11 Canton, NY 13617 315/386-4578 (T) 315/386-1012 (F)

Elmira 2330 Route 352 Elmira, NY 14903 607/737-0700 (T) 607/737-0714 (F)

Plattsburgh 130 Arizona Ave Plattsburgh, NY 12903 518/563-5878 (T) 518/562-1321 (F)

Poughkeepsie 251 Upper North Road Highland, NY 12528 845/691-6098 (T) 845/691-6099 (F)

Rochester 3445 Winton Place Rochester, NY 14623 585/427-9020 (T) 585/427-9021 (F)

Syracuse 6085 Court Street Road Syracuse, NY 13206 315/699-5281 (T) 315/699-3374 (F)

Utica 301 St. Anthony Street Utica, NY 13501 315/735-3309 (T) 315/735-0742 (F)

Watertown 26581 NYS Route 283 Watertown, NY 13601 315/786-7887 (T) 315/786-2022 (F)

Project No.		Project Name		Date Collected		Laboratory Instructions			Report Distribution		
P2889		Essex Co. Gov. Ctr.		6/2/17		<input type="checkbox"/> 12hr <input type="checkbox"/> 24hr <input type="checkbox"/> 48hr <input type="checkbox"/> 72hr <input checked="" type="checkbox"/> 5day <input type="checkbox"/>			Send Reports To (ATL Office): ATL Contact: <i>Christian Foot</i> Send Copy To: <i>Emil</i> <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		
Project Contact:		Social Services Wing		Turn-Around Time:		<input checked="" type="checkbox"/> Positive Stop Analysis <input checked="" type="checkbox"/> If negative by PLM-NOB, analyze by TEM-NOB <input type="checkbox"/> Other			ATL Contact: <i>Christian Foot</i> Email: <i>emil@atlantictesting.com</i>		
Project Location:		Elizabeth Center, NY		Special Instructions:							
Field Sample No.	Sample Location	Sample Description	PLM NOB	PLM-NOB	TEM-NOB	TEM-ONLY	MICRO-VAC	Laboratory Sample ID No.			
P15659A021A-060217	Basement - Kitchen	Light Green 9x9 Floor tile	X	X	X						
P15659A021B-060217	Basement - Corridor	Light Green 9x9 Floor tile	X	X	X						
P15659A021A-060217	Basement - Kitchen	Black mastic on a1	X	X	X						
P15659A021B-060217	Basement - Corridor	Black mastic on a1	X	X	X						
P15659A021A-060217	Basement - Corridor	Brown 12x12 Floor tile with white streaks	X	X	X						
P15659A021B-060217	Basement - Corridor	Brown 12x12 Floor tile with white streaks	X	X	X						
P15659A021A-060217	Basement - Corridor	Yellow mastic on a3	X	X	X						
P15659A021B-060217	Basement - Corridor	Yellow mastic on a3	X	X	X						
P15659A021A-060217	Basement Corridor	Green 12x12 Floor tile with Brown streaks	X	X	X						
P15659A021B-060217	Basement Corridor	Green 12x12 Floor tile with Brown streaks	X	X	X						
P15659A021A-060217	Basement Corridor	Yellow mastic on a5	X	X	X						
P15659A021B-060217	Basement Corridor	Yellow mastic on a5	X	X	X						
Sampler's Name: <i>Seremy Fessette</i>		Date: 6/2/17		Received at Laboratory (Name):		Date:		Shipment Rec'd Intact			
Sampler's Signature: <i>Seremy Fessette</i>		Time: 0430		Laboratory Signature:		Time:		<input type="checkbox"/> YES <input type="checkbox"/> NO			
Samples Refiniquished By: <i>Seremy Fessette</i>											
Name: <i>Seremy Fessette</i>		Date: 6/1/17		Name: <i>Joseph</i>		Date: 6/5/17		Field and Laboratory Remarks:			
Signature: <i>Seremy Fessette</i>		Time: 1700		Signature:		Time: 1100					
Name:		Date:		Name:		Date:					
Signature:		Time:		Signature:		Time:					

Think Quality

#217061637

Distribution: White with Samples
Yellow to Laboratory
Pink to ATL Files