

ADDENDUM NO. 5

to the Contract Documents
for the Construction of the

Jay Community Center Emergency Shelter Upgrades

at
11 SCHOOL LANE
AU SABLE FORKS, NY 12912

TO ALL HOLDERS OF CONTRACT DOCUMENTS:

Your attention is directed to the following interpretations of changes in and additions to the Contract Documents for the construction of the **JAY COMMUNITY CENTER EMERGENCY SHELTER UPGRADES** project at the Jay Town Hall Au Sable Forks, New York. This Addendum is part of the Contract Documents in accordance with the provisions of General Conditions, Article 1.1.

GENERAL:

1. Refer to this document for summary of responses to inquiries received.
2. There is no change to the bid opening date and time.

RFI CLARIFICATIONS:

Q: Alternate 2 instructs the contractor to install the hot water lines from new tank (to kitchen) as base bid work. All work related to the kitchen is the alternate. If we install only base bid work, there will be not domestic hot and cold-water piping supplying the women's room.

A: All associated piping to Women's Bathroom is in the base bid. Kitchen domestic water piping mains is base bid. Install branch T's and ball valves for alternate kitchen connection in the base bid.

END OF ADDENDUM

C&S ENGINEERS, INC.



D.H. Chung, AIA LEED AP
Senior Project Architect