



# ESSEX COUNTY OFFICE OF THE MANAGER

7551 Court Street · P.O. Box 217 · Elizabethtown, New York 12932  
Telephone (518) 873-3332 · Fax (518) 873-3339

Daniel L. Palmer  
County Manager

Linda M. Wolf  
Purchasing Agent

**TO:** All Bidders

**FROM:** Linda Wolf, CPA, Purchasing Agent

**DATE:** July 17, 2020

**SUBJECT:** Addendum #4 INSTALLATION OF A REINFORCED CONCRETE BOX CULVERT

**This Addendum, issued to bid document holders of record, indicates changes to the bid documents for the *Installation of a Reinforced Concrete Box Culvert Bid Opening July 23, 2020.***

**Please see additional information below:**

- 1) The heaviest pick weight for the culverts is: 45,400#
- 2) Stream Stats probability predictions for flow:

Statistic	Value	Unit	SEp
0.01 Percent Duration	134	ft <sup>3</sup> /s	23
1 Percent Duration	38.5	ft <sup>3</sup> /s	14
5 Percent Duration	16.1	ft <sup>3</sup> /s	8.8
10 Percent Duration	10.6	ft <sup>3</sup> /s	7.3
15 Percent Duration	7.58	ft <sup>3</sup> /s	6.6
20 Percent Duration	5.92	ft <sup>3</sup> /s	7
25 Percent Duration	4.82	ft <sup>3</sup> /s	7.2
35 Percent Duration	3.41	ft <sup>3</sup> /s	8.7
50 Percent Duration	2.45	ft <sup>3</sup> /s	11
65 Percent Duration	1.74	ft <sup>3</sup> /s	14
75 Percent Duration	1.5	ft <sup>3</sup> /s	22
80 Percent Duration	1.22	ft <sup>3</sup> /s	26
85 Percent Duration	0.969	ft <sup>3</sup> /s	31
90 Percent Duration	0.76	ft <sup>3</sup> /s	38

END OF ADDENDUM # 4