



ESSEX COUNTY OFFICE OF THE MANAGER

7551 Court Street · P.O. Box 217 · Elizabethtown, New York 12932
Telephone (518) 873-3332 · Fax (518) 873-3339

Daniel L. Palmer
County Manager

Linda M. Wolf
Purchasing Agent

TO: All Bidders
FROM: Linda Wolf, CPA, Purchasing Agent
DATE: May 26, 2022
SUBJECT: Addendum #1 VRLA BATTERIES

This Addendum, issued to bid document holders of record, indicates changes to the bid documents for the VRLA Battery Installation Bid Opening June 8, 2022.

PLEASE note the following Questions & Answers:

Question:

Please list of equipment to be serviced including Make/Model details.

Answer:

Eighty (80) Item # ENERSYS 12HX400 Batteries to be installed in the Liebert UPS Part Number 37SA130AAC6EA26 (Serial #37-7360)

Question:

What is the level of coverage (24x7 emergency service with parts/labor/travel coverage with PM(s) or PM Only service)?

Answer:

Two Preventative Maintenance Services annually with IR scan between 8am-4:30 Monday-Friday (excluding national holidays)

Question:

What is the Quantity & Timeframe of PMs?

Answer:

Guaranteed 4-hour on-site emergency response, 7 days a week 24 hours a day

Question:

What should be included in the 3 year Maintenance Agreement?

Answer:

· Two Preventative Maintenance Services annually with IR scan between 8am-4:30 Monday-Friday (excluding national holidays)

- Guaranteed 4-hour on-site emergency response, 7 days a week 24 hours a day
- Full service including parts, labor, and travel

Question:

Does each battery cabinet have an individual breaker?

Answer:

Yes, each cabinet has a breaker?

Question:

Are there any delivery obstructions such as curbs, stairs, narrow hallways or doorways that we should be aware of?

Answer:

No obstructions and elevator on site.

END OF ADDENDUM # 1