



ESSEX COUNTY

OFFICE OF THE MANAGER

7551 Court Street · P.O. Box 217 · Elizabethtown, New York 12932
Telephone (518) 873-3332 · Fax (518) 873-3339

Michael Mascarenas
County Manager

Linda M. Wolf
Purchasing Agent

TO: All Bidders

FROM: Linda Wolf, CPA, Purchasing Agent

DATE: May 27, 2026

SUBJECT: Addendum #1 Bid for RIVER ROAD (CR18) STEEL SHEET PILES

This Addendum, issued to bid document holders of record, indicates changes to the bid documents for the *RIVER ROAD (CR18) STEEL SHEET PILES* bid opening June 4th, 2026.

PLEASE NOTE THE FOLLOWING QUESTIONS & ANSWERS:

Question #1:

Please confirm whether SKP9 and SKP90 are identical or different.

Answer #1:

There is a typo in the Bid Documents. The corner connection type should be **SKP90**, not SKP9.

Question #2:

What are the specific ASTM standards that apply to this product?

Answer #2:

ASTM A572 Gr. 50 (min.). The other option is ASTM A588 (weathering steel), which isn't recommended for submerged applications.

Question #3:

What is the specific delivery address?

Answer #3:

Essex County Dept of Public Works, 8053 U.S. Route 9, Elizabethtown, NY 12932

END OF ADDENDUM # 1