



ADDENDUM No. 1

Project Name: Water and Sewer Upgrades
Town of Moriah

Addendum Date: January 16, 2020

To: All Contract Bidders of Record

This addendum forms a part of the Contract Documents and modifies the original Drawings and Specifications dated December 2019. All contract bidders must acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the bidder to disqualification.

Instructions to Bidders

1. Revise Paragraph 22. to read as follows:

22. MWBE Participation and Goals

Under 5 NYCRR Section 142.8, Contractor is required to make “good faith efforts” to provide meaningful participation to Minority & Women-Owned Business Enterprises (MWBEs). An overall goal of 30% has been established for this project based on a combination of 15% MBE and 15% WBE participation. Upon contract award, Contractor will be required to prepare an M/WBE Utilization Plan to demonstrate M/WBE participation, prior to contract execution and Notice to Proceed.

Bid Form

1. Remove Base Bid Item 7A in its entirety.
2. Revise Base Bid Item 7B Estimated Quantity to be 490 LF.

Specification Section 333913 - Manhole Structures

1. Revise Section 333913 Part 2.1.C.1 to read as follows:

“1. All precast structures shall be waterproofed on the inside and outside with two (2) coats of a two-component coal tar epoxy coating.

a. Acceptable Coating: Hi-Mil Sher-Tar B6940 by The Sherwin-Williams Company, Cooper Black No. 775 Epoxy Tar Coating by Coopers Creek Chemical Corporation, or approved equal.

2. Revise Section 333913 Part 3.1.C to read as follows:

“Paint interior and exterior concrete surfaces of structure, with two (2) coats of coal tar epoxy applied at 8-12 mils DFT per coat.”